



Annual Drinking Water Quality Report for Calendar Year 2008

Otter Lake Water Commission

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. This report includes drinking water facts, information on violations (if applicable), and contaminants detected in your drinking water supply during calendar year 2008. Each year, we will provide you a new report. If you need help understanding this report or have general questions, please contact the person listed below.

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Contact Name: Robert Dill
 Telephone Number: (217) 965-1566
 E-mail (if available) otterlake@otterlakewater.net

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings on the 2nd Thursday of the month at 7:00 pm. These meetings are held at the Commission office at 6475 W Montgomery Road in Virden. This report is also available on our website at www.otterlakewater.net.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Source Water Name	Type of Water	Report Status	Location
INTAKE (58059) OTTER LAKE	SW	_____	Outside the city limits of Girard

Other Facts about Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Source Water Assessments

Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion.

Otter Lake is utilized by the Otter Lake Water Commission (Facility # 1175200) to provide water to eight communities in Christian, Sangamon and Macoupin Counties and the surrounding rural areas. This facility draws water from Otter Lake through one surface water intake (IEPA #58059). The water is obtained via two 700 and one 1,400 gallon per minute pumps located on an elevated fill roadway bisecting the lake. The supply provides approximately 1.5 million gallons per day to 466 service connections and an estimated population of 16,996. Eight facilities purchase water from the Commission, including Auburn (1670050), Divernon (1670450), Girard (1170450), Pawnee (1670850), Thayer 1671250), Virden (1171100), Nilwood (1170750) and Tovey.

The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by the Water Commission office or call our operator at (217) 965-1566. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

2008 Regulated Contaminants Detected

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. --- If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. ---

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Lead and Copper								
	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	07/23/2007	1.3	1.3	.147	0	ppm	N	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	07/23/2007	0	15	1.25	0	ppb	N	Corrosion of household plumbing systems; erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

ppm: milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.

ppb: micrograms per liter or parts per billion – or one ounce in 7,350 gallons of water.

na: not applicable.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Regulated Contaminants

Disinfectants & Disinfection Byproducts	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine		1.4	.25 – 1.4	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Chlorite		.6	.25 - .6	0.8	1	ppm	N	By-product of drinking water chlorination.
Haloacetic Acids (HAA5)*		34	22.06 – 32.7	No goal for the total	60	ppb	N	By-product of drinking water chlorination.
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.								
Total Trihalomethanes (TTHM)*		64	34.9 – 58.93	No goal for the total	80	ppb	N	By-product of drinking water chlorination.
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.								
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic		1	.944 - .944		10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium		.0194	.0194 - .0194	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium		1	1.46 – 1.46	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride		.8	.76 - .76	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Sodium		9	8630 – 8630			ppm	N	Erosion from naturally occurring deposits: Used in water softener regeneration.
Zinc		.004	.00439 - .00439	5	5	ppm	N	Erosion from naturally occurring deposits.
Synthetic Organic Contaminants (pesticides and herbicides)	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine		.3	0 - .3	3	3	ppb	N	Runoff from herbicide used on row crops.

Turbidity				
Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.				
	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Lowest Monthly % Meeting Limit	0.3 NTU	100%	N	Soil Runoff
Highest Single Measurement	1 NTU	0.29 NTU	N	Soil Runoff

Total Organic Carbon	
The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.	